West Bengal State Electricity Transmission Company ltd.

(A West Bengal Government Enterprise)

Vidyut Bhavan, Block – DJ, Sector – II, Salt Lake, Kolkata – 700 091

NOTICE

Gist of the Application for Investment Approval of Transmission Projects:

1. West Bengal State Electricity Transmission Company Limited (in short 'WBSETCL') has submitted application before the West Bengal Electricity Regulatory Commission (in short 'Commission') for investment approval of Rs. 34289.93Lakh in connection with implementation ofnew transmission schemein terms of Regulation 2.8.2.3 of the West Bengal Electricity Regulatory Commission (Terms and Conditions of Tariff) Regulations, 2011, as amended. The application has been admitted by the Commission in Case No:OA-475/23-24.

2. The brief description of the schemesis as follows:

Sr. No.	Description	Project Cost (Rs. in Lakh)
1.	Upgradation of Barjora 132/33KV Substation to 220/132/33KV Substation by construction of 220KV GIS and associated transmission system.	15355.35
2.	D/C LILO of Durgapur-Barjora 132KV D/C Transmission Line (at tower location no 18) at Bamunara 132KV Sub-station by using underground cable (D/C RL≈ 1.55Km (UG))along with construction of 04 nos. 132KV Line bays at Bamunara 132KV Substation.	7094.91
3.	Replacement of Existing Panther Conductor by high capacity HTLS Conductor along with 132KV CT i.r.o different 132KV D/C Transmission lines of WBSETCL.	11707.95
4.	LILO of 400KV PPSP-Durgapur S/C transmission line at proposed BAPL 400KV Substation. (S/C RL≈ 0.55Km).	131.72
5.	**Total Project Cost**	**34289.93**

3. Application submitted by WBSETCL may be inspected at the office of the Commission at Plot No: AH/5 (2nd Floor& 4th Floor) Premises No: MAR 16-1111, Action Area – 1A, Newtown, Rajarhat, Kolkata – 700163 [e-mail: cp-wberc@gov.in]following the procedures as laid down in the West Bengal Electricity Regulatory Commission (Conduct of Business) Regulations, 2013,as amended, from11-00 AM to 05-00 PM on all working days uptoone day prior to the last day of submission of suggestions, objections and comments.

4. The application has been posted on the website of WBSETCL at www.wbsetcl.in.

5. The suggestions,objections and comments if any, on the proposal contained in the application may be submitted at the office ofthe Commission at the above-mentioned address from 11 AM to 5 PM on all working days within21 (twenty-one) days from the date of publication (including the date of publication) of this notice in the newspaper.

6. The gist has been published with the approval of the Commission.

Place: Salt Lake, Kolkata (DebashisChaki)

Date: Chief Engineer (CPD)