

West Bengal State Electricity Transmission Company Ltd.

(A West Bengal Government Enterprise)

Vidyut Bhavan, Block - DJ, Sector - II, Salt Lake, Kolkata - 700 091



NOTICE

Gist of the Application for Investment Approval of Transmission Projects

1. West Bengal State Electricity Transmission Company Limited (in short "WBSETCL") has submitted an application on 14.12.2020 before the West Bengal Electricity Regulatory Commission (hereinafter referred to as "Commission") seeking investment approval for an estimated cost of ₹ 21236.40 Lakhs in connection with establishment of 220/132/33 kV Gas Insulated Sub-station at Falakata, District - Alipurduar and Associated Transmission System in terms of regulation 2.8.2.3 of the West Bengal Electricity Regulatory Commission (Terms and Conditions of Tariff) Regulations, 2011, as amended. The application has been admitted by the commission on 09/02/2021 in Case No: OA-350/20-21.
2. The brief description of the scheme is as follows :

Sl. No.	Description	Project Cost (Rs in Lakh)
1.	Construction of Falakata 220/132/33 kV GIS with 4 no 220 kV feeder bays, 4 no 132 kV feeder bays, 2x160 MVA 220/132 kV Transformers, 2x50.0 MVA 132/33 kV Transformers, 12 no 33 kV feeder bays.	21236.40
	D/C LIL0 of Birpara - Alipurduar 220 kV D/C line of PGCIL at proposed Falakata 220 kV GIS (Route Length ≈ 7.5 KM D/C & 0.30 KM M/C).	
	132 kV D/C Transmission line from nearest point of Coochbehar - Mathabhanga 132 kV D/C line to proposed Falakata 220 kV GIS to establish D/C connectivity between Falakata 220 kV & Mathabhanga 132 kV GIS (Route Length ≈ 25.50 KM D/C).	
	132 kV D/C Transmission line from nearest point of Coochbehar - Dinhat - Mathabhanga 132 kV D/C line to proposed Falakata 220 kV GIS to establish S/C connectivity of Falakata 220 kV GIS with Coochbehar 132 kV SS & Dinhat 132 kV GIS (Route Length ≈ 23.00 KM D/C).	

3. Application dated 14.12.2020 submitted by WBSETCL may be inspected at the office of the Commission at Plot No: AH/5 (2nd Floor & 4th Floor) Premises No: MAR 16-1111, Action Area - 1A, Newtown, Rajarhat, Kolkata - 700163 [Telephone No: (033) 2962-3756 and FAX: (033) 2962-3757, e-mail : cp-wberc@gov.in] and certified copies of the application or part thereof may also be obtained from the office of the Commission following the procedures as laid down in West Bengal Electricity Regulatory Commission (Conduct of Business) Regulations, 2013 during office hours on all working days up to the last date of submitting suggestion and objections.
4. The application of WBSETCL for approval of the capital expenditure has been posted on the website of WBSETCL at www.wbsetcl.in.
5. The Objections and suggestions, if any, on the proposals contained in the application may be submitted at the office of the Commission mentioned above within fourteen (14) days (including the date of publication) of publication of this notice in the newspaper.
6. The gist has been published with the approval of the Commission.

Place: Salt Lake, Kolkata

Date : 12/02/2021

(Asit Karmakar)
Chief Engineer (CPD)


SL. No. 278.../20.20



पश्चिमबङ्ग पश्चिम बंगाल WEST BENGAL
BEFORE THE WEST BENGAL PUBLIC
AT BIDHANNAGAR
DIST. NORTH 24 PARAGANAS

Z 999047

**BEFORE THE WEST BENGAL ELECTRICITY REGULATORY
COMMISSION, KOLKATA**



File no. _____

Case no. _____

In the matter of :

Application for approval of incurring Capital Expenditure of an estimated cost ₹ 21236.40 Lakh for establishment of 220/132/33 kV Gas Insulated Sub-station at Falakata, District - Alipurduar and Associated Transmission System. This is in terms of Regulation 2.8.2.3 and Paragraph 4.1 (vi) of Schedule-2 of the West Bengal Electricity Regulatory Commission (Terms and Condition of Tariff) Regulations, 2011, as amended.

AND

In the matter of :

West Bengal State Electricity Transmission Company Limited, Vidyut Bhavan, Block - DJ, Sector - II, Bidhannagar, Kolkata - 700091.

ATTESTED
S. CHAUDHURI
* NOTARY *
GOVT. OF INDIA
Regd. No.-6584/08
Bidhannagar Court
Dist.-North 24 Pgs

14 DEC 2020


১৬
..... মূল কপি
W.B.S.E.T.C Ltd.
.....
Biddhut Bhawan, Jekhoke-Kat-91

এ. ডি. এস. আর. অফিস, মগরাহাট
দক্ষিণ ২৪ পরগণা

ভেশ্বার : আসাদুর রহমান

.....
.....

01 SEP 2020



Affidavit verifying the petition / reply / application.

I, Sri Asit Karmakar, Son of Late Panchanan Karmakar, aged 59 years residing at Flat No. - 1B, Trina Co-operative Housing Society, Plot No. - BA 71, New Town AA-I, Kolkata - 700 156 do solemnly affirm and say as follows :

I am the Chief Engineer, Central Planning Department of the West Bengal State Electricity Transmission Company Limited (WBSETCL), petitioner in the above matter, and I am duly authorized by the said petitioner to make this affidavit for and on its behalf.


The statements made in the petition herein now shown to me and marked with the letter 'A' are true to my knowledge and based on information received and are true to my belief and nothing material has been concealed from the statements so made of documents or supporting data etc. attached.

Solemnly affirmed at Kolkata on this 11th day of December, 2020 that the contents of this affidavit are true to my knowledge, no part of it is false of nothing material has been concealed there form and misleading material included therein.

Place : Kolkata

Date : 14/12/2020


(ASIT KARMAKAR)
Chief Engineer
Central Planning Department
WBSETCL


ATTESTED
S. CHAUDHURI
* NOTARY *
GOVT. OF INDIA
Regd. No. -6584/08
Bidhannagar Court
Dist.-North 24 Pgs

14 DEC 2020

A

**BEFORE THE HON'BLE WEST BENGAL ELECTRICITY
REGULATORY COMMISSION**

In the matter of : Application for approval of incurring Capital Expenditure of an estimated cost ₹ 21236.40 Lakh for establishment of 220/132/33 kV Gas Insulated Sub-station at Falakata, District - Alipurduar and Associated Transmission System. This is in terms of Regulation 2.8.2.3 and Paragraph 4.1 (vi) of Schedule-2 of the West Bengal Electricity Regulatory Commission (Terms and Condition of Tariff) Regulations, 2011, as amended.



AND

In the matter of : West Bengal State Electricity Transmission Company Ltd., Vidyut Bhavan, Block - DJ, Sec - II, Bidhannagar, Kolkata -700091

Respectfully Sheweth :-

1. The petitioner is a Transmission Licensee under Electricity Act, 2003 having its Head Office at Vidyut Bhavan, Block - DJ, Sector - II, Bidhannagar, Kolkata - 700091.
2. In terms of Regulation 2.8.2.3 and Paragraph 4.1 (vi) of Schedule - 2 of West Bengal Electricity Regulatory Commission (Terms and Condition of Tariff) Regulations, 2011, as amended, the Transmission Licensee (WBSETCL) is required to seek Hon'ble Commission's approval prior to incurring capital expenditure. These regulations were notified in the Kolkata Gazette vide notification No. : 49/WBERC dt : 27/08/12.
3. Name of the Project : Establishment of 220/132/33 kV Gas Insulated Substation at Falakata, District Alipurduar and associated transmission system.
4. Project Details :
 - ✓ Construction of Falakata 220/132/33 kV GIS with
 - 4 no 220 kV feeder bays,
 - 2x160 MVA 220/132 kV Transformer,
 - 4 no 132 kV feeder bay,
 - 2x50.0 MVA 132/33 kV Transformers &
 - 12 no 33 kV feeder bays.
 - ✓ D/C LILO of Alipurduar - Birpara 220 kV D/C line of PGCIL at proposed Falakata (Route Length ≈ 7.5 KM D/C & 0.30 KM M/C).
 - ✓ 132 kV D/C Transmission line from nearest point of Coochbehar - Mathabhanga 132 kV D/C line to proposed Falakata 220 kV GIS to establish D/C connectivity between Falakata 220 kV & Mathabhanga 132 kV GIS (Route Length ≈ 25.50 KM D/C).

Sudip Chaudhuri
ATTESTED
S. CHAUDHURI
* NOTARY *
GOVT. OF INDIA
Regd. No. - 6584/2008
Bidhannagar Court
Dist. - North 24 Pgs.

14 DEC 2020

[Signature] Page 1 of 4

